

LEGEND

- HIGH LEVEL PIPEWORK
- LOW LEVEL PIPEWORK
- [Symbol] EXISTING SERVICES TO REMAIN
- [Symbol] NEW SERVICES
- [Symbol] EXISTING SERVICES TO BE REMOVED OR RELOCATED
- ⊙ THERMOSTAT
- WATER HEATER REFERENCE
- ⊙ THERMOSTATE LOCATION WITH DIMENSION FROM WALL/POINT AS SHOWN. (CIRCLE DENOTED AREA SERVED) HEIGHT WILL BE 1500mm UNLESS STATED OTHERWISE

SPRINKLERS

- E EXISTING TO REMAIN
- R EXISTING TO BE RELOCATED
- N NEW
- D DELETE

NOTE


1. FOR DETAILED SPRINKLER MODIFICATIONS REFER TO BLUE SHIELD DRAWINGS

2. MAIN CONTRACTOR TO ALLOW PROVISION IN NOISE BARRIER FOR ACCESS TO FCU BARRIER CONTROLS WHERE SITUATED ADJACENT.

NEW 1000mm DIFFUSER TO MATCH EXISTING COMPLETE WITH PLENUM.

FLAT DUCT TO BE USED WHERE NEW DUCT PASSES BELOW BEAM.

FLAT DUCT TO BE USED WHERE NEW DUCT PASSES BELOW BEAM. PLENUMS MANUFACTURED TO AVOID SERVICES AND DEEP BEAMS ABOVE



- 35mm# TRAPPED WASTE & 15mm# CWS UNDER BENCH HWH.
- SERVICES TO RUN L/L UNDER BENCH.
- 42mm# TRAPPED WASTE & 15mm# CWS & 15mm# HWS TO SINK UNIT.
- 35mm# ASP DROP TO L/L.
- EXISTING WP RISER, CONNECT 42mm# WP AT L/L.
- EXISTING ASP RISER, CONNECT 35mm# ASP AT H/L.
- EXISTING CWS RISER, CONNECT 15mm# CWS AT H/L.

THIS THERMOSTAT TO SERVE FCU's B05.07 & 09

© copyright		Client	CLIENT1 CLIENT2	
		Contract	CONTRACT1 CONTRACT2	
		Drawing Title	TITLE1 TITLE2	
Scale	Date	Date	Drawn	DRAWN
Revision	DATE	DESCRIPTION	DRAWN	Revision
DRAWING_NO		REV		